



## FIRE RESISTANT TIMBER DOOR SCHEME

**Certificate number: IFCC 1266**

*Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

### **David Smith St Ives Limited**

Marley Road  
St Ives  
Huntingdon  
Cambridgeshire PE27 3EX  
01480 309900  
[doors@davidsmith.co.uk](mailto:doors@davidsmith.co.uk)

Who fabricate the following timber fire doors and or doorsets:

### **DSJ Joinery Doors**

have satisfied the requirements of the SDP01 Fire resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve for **30 minutes to 60 minutes integrity** are detailed on page 2 of this certificate.



First Issued: 27 September 2016  
Revised: 16 June 2022  
Valid to: 26 September 2026  
Issue No: 3



175

Ian Woodhouse  
Director of Certification

---

IFC Certification Ltd  
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

F27 ©IFC Certification Ltd 2004

## ***Certificate number: IFCC 1266***

The production of fire resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

<b>Doorset Description</b>	<b>Fire Rating</b>	<b>Assessment/ Test Report</b>
DSJ 30	FD30	Chilt A09136
DSJ 60	FD60	Chilt A09165

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

**It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.**

**Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.**