



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1265

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd, part of the Kiwa UK Group

This is to certify that

David Smith St Ives Limited

Marley Road
St Ives
Huntingdon
Cambridgeshire PE27 3EX
Tel: 01480 309900
Email: doors@davidsmith.co.uk

Who fabricate the following flush door ranges of timber fire doors and or doorsets:

**DSF FD30, FD60. DSTm FD30, FD60.
DSP FD30, FD60, FD90, FD120.
DSA FD30, FD60, FD90.
DSXL FD30, FD60.**

have satisfied the requirements of the SDP 01 Timber Fire Door scheme v3.8. This includes the testing of products to **BS476: Part 22: 1987**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed on page 2 of this certificate.

Initial Certification: 25 October 2016
Re-issued: 28 October 2021
Revised: 01 October 2024
Valid to: 24 October 2026
Issue number: 5

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*

CERTIFICATE



CERTIFICATE

The production of fire-resistant timber doorsets are manufactured in accordance with schedules referenced within the following table:

Doorset Description	Fire Rating	Schedule
DSF	FD30, FD60	IFCC1265-DSF01
DSP	FD30, FD60, FD90, FD120	IFCC1265-DSP02
DSTm	FD30, FD60	IFCC1265-DSTm04
DSA	FD30, FD60, FD90	IFCC1265-DSA05
DSXL	FD30, FD60	IFCC1265-DSXL07

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder’s responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

