



FIRE RESISTANT PARTITION SCHEME

Certificate number: IFCC 1267

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd, part of the Kiwa UK Group

This is to certify that

David Smith St Ives Limited

Marley Road
St Ives
Huntingdon
Cambridgeshire PE27 3EX
Tel: 01480 309900
Email: doors@davidsmith.co.uk

Who fabricate the following timber framed partitions / screens:

DSJ Screens

have satisfied the requirements of the SDP 21 Fire Rated Partition scheme v2.1. This includes the testing of products to **BS476: Part 22: 1987**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity** are detailed on page 2 of this certificate.

Initial Certification: 27 September 2016


Revised: 01 October 2024

Valid to: 26 September 2026

Issue number: 4

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



The production of fire-resistant screens are manufactured in accordance with assessment / test reports referenced within the following table:

Product Description	Fire Rating	Assessment / Test report
DS Screens	FD30, FD60	PAR/9334/01

Signed on behalf of Kiwa UK

David Mowatt
Head of IFC Certification /
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

CERTIFICATE

